

MATERIAL


CASTING - BRONZE ALLOY HARDWARE - SILICONE BRONZE OR STAINLESS STEEL

NOTES:

1. NUMBER OF U-BOLT CLAMPS TO BE USED IS TO BE BASED ON A SPACING OF 36" MAXIMUM TO ATTACH AIR TERMINALS AND/OR DOWN CONDUCTOR TO SUPPORT.
2. ORDER PROPER SIZE U-BOLT CLAMP TO FIT CABLE, SDT-1010 OR LARGER.


U-BOLT TYPE CLAMP DETAIL "1"

DOWN CONDUCTOR OR AIR TERMINAL TO PIPE AIR TERMINAL STANDARD NOT TO SCALE




DETAIL "2"

CABLE TO CABLE CROSS CONNECTION DETAIL




<u>DETAIL "3"</u>

<u>CABLE TO CABLE "T" CONNECTION DETAIL</u>




DETAIL "4"

GROUNDING TO COUNTERPOISE DETAIL




DETAIL "5"

GROUND ROD CONNECTION DETAIL




DETAIL "6"

CABLE TO GROUND ROD DETAIL




<u>DETAIL "7"</u>

CABLE TO GROUND PLATE DETAIL




DETAIL "8"


GROUND ACCESS WELL DETAIL



MAIN GROUND PLATE DETAIL NOT TO SCALE



MISCELLANEOUS BONDS AND CLAMPS NOT TO SCALE



DETAIL "9"

GROUND ROD LOCATOR BOX

NOTES:

- 1. ALL MAIN CONDUCTORS AND DOWN CONDUCTORS SHALL BE IN ACCORDANCE WITH NFPA 780 LIGHTNING PROTECTION CODE.
- FOR CLASS I CONDUCTOR: CONDUCTOR SHALL BE THOMPSON 32S OR APPROVED
- FOR CLASS II CONDUCTOR: CONDUCTOR SHALL BE THOMPSON 28R FOR BUILDINGS OR STRUCTURES UP TO 125'-0" TALL.
- CONDUCTOR SHALL BE THOMPSON 507 FOR ALL STRUCTURES MORE THAN 125'-0" TALL OR APPROVED EQUAL.
- DOWN CONDUCTOR BEND RADIUS SHALL BE $8^{\prime\prime}$ MINIMUM. NO BEND OF A CONDUCTOR SHALL FORM AN INCLUDED ANGLE OF LESS THAN 90 DEGREES.
- 2. DISTANCE BETWEEN CLAMPS ATTACHING CONDUCTORS TO SUPPORT SHALL BE 36" MAX
- 3. SCRAPE BONDING SURFACES UNDER CLAMPS AND BRACKETS TO BARE METAL, SECURE HARDWARE AND COAT WITH ZINC RICH COMPOUND.
- 4. INSTALL BURIED COUNTERPOISE 24" BELOW GRADE AND 2 FEET TO 6 FEET FROM STRUCTURE BEING PROTECTED.
- 5. INSTALL THOMPSON #28R OR #507 DOWN CONDUCTORS. FASTEN TO STRUCTURE
- 6. ROUTE DOWN CONDUCTORS FROM EACH CORNER OF BUILDING OR STRUCTURE. DO NOT ROUTE DOWN CONDUCTORS WITH OTHER ELECTRICAL CABLES.
- 7. CONNECT GROUNDING ELECTRODE SYSTEM SHOWN TO ANY ADJACENT OR NEAR VICINITY GROUNDING SYSTEM USING BARE #4/O AWG COPPER CABLE BURIED 24" BELOW GRADE WITH EXOTHERMIC WELD CONNECTIONS.

WITH THOMPSON #142HD FLAT CLAMP OR EQUAL PER NOTES 2 AND 3.

- 8. EXTEND CABLE 1" (MAX) BEYOND TERMINATING CONNECTIONS AND FITTINGS.
- 9. ALL HARDWARE SHALL BE COPPER, BRONZE OR STAINLESS STEEL. NO ALUMINUM CABLE OR HARDWARE SHALL BE USED.
- 10. USE DRIVING STUD OR NUT TO PREVENT DAMAGE TO DRIVEN END OF GROUND ROD AND PERMIT PLACING EXOTHERMIC WELD MOLD AT TOP OF GROUND ROD WHEN IT HAS REACHED IT'S INTENDED DEPTH.
- 11. CONNECT MAIN GROUND CABLE TO INSULATED GROUND PLATE INSIDE BUILDING WITH COPPER ALLOY GROUND LUG.
- 12. WHERE GROUND RODS CANNOT BE DRIVEN INTO THE EARTH, SUBSTITUTE 24"x24"x1/4" THICK COPPER GROUND PLATES IF APPROVED BY THE RESIDENT ENGINEER. PLATES SHALL BE INSTALLED VERTICALLY WITH THE TOPS OF THE PLATES NOT CLOSER THAN 12" TO THE GROUNDLINE.
- 13. THE GROUNDING ELECTRODE CONDUCTOR FOR THE ELECTRIC SERVICE SHALL BE CONNECTED TO A NEW 3/4"x10' COPPERCIAD GROUND ROD WITH AN EXOTHERMIC WELD. THE 4/0 COUNTERPOISE SHALL BE EXOTHERMICALLY WELDED TO THE SAME GROUND ROD.
- 14. DOWN CONDUCTORS SHALL BE INTERCONNECTED BY A HALO RING TYING TOGETHER ALL AIR TERMINALS FORMING A TWO-WAY PATH HORIZONTALLY AND DOWNWARD TO CONNECT DIRECTLY TO A GROUND ROD ON EARTH ELECTRODE SYSTEM.
- 15. CABLE CONNECTIONS TO ALL GROUND PLATES SHALL BE MADE WITH COPPER ALLOY GROUND LUGS.
- 16. GROUND ROD LOCATOR BOX INSTALL PVC SPRINKLER ACCESS WELLS WITH COVERS OVER NEW AND EXPOSED GROUND RODS. WELLS USED FOR FUTURE DIAGNOSIS.

D	05/12/2004	ADDED MAIN GROUND PLATE DETAIL & MISC BONDS/CLAMPS	DKL	DKL
С	08/29/2001	ADDED DETAIL 9 & NOTE 16	JVI	JVI
В	08/28/2001	UPDATED DETAILS	JVI	JVI
Α	05/23/2000	UPDATED DETAILS	JRD	DKR
REV	DATE	DESCRIPTION	CHECK	APRV'D
			•	

DEPARTMENT OF TRANSPORTATION FEDERAL AVIATION ADMINISTRATION NORTHWEST MOUNTAIN REGION - SEATTLE, WASHINGTON

STANDARD

GROUNDING DETAILS

REVIEWED BY	SUBMITTED BY		APPROVED BY
	KRIS E. FI	RAME	MICHAEL A. DASOVICH
	SUPV: REFURB. UNIT		MANAGER: ENVIRONMENTAL ENGR.
	DESIGNED:	ISSUED BY	DATE 03/05/1993
	DRAWN: T.O	AIRWAY FACILITIES DIVISION ANM-400	DRAWING NO.
	CHECKED: M.N		NMD-000-92-22

